

# Zertifikat *Certificate*

**Zertifikatsnummer Certificate No.:**

R 50658154 0001

**Berichtsnummer Report No.:**

CN24J02U 001

**Genehmigungsinhaber License Holder:**

Zhejiang Tengen Electric Co., Ltd.  
Sulv Industrial Area,  
Liushi Town, Yueqing City,  
325604 Zhejiang  
P.R. China

**Fertigungsstätte Manufacturing Site:**

Zhejiang Tengen Electric Co., Ltd.  
(Yueqing Economic  
Development Zone Branch)  
No.288 Central Avenue  
Development Zone, Yueqing City,  
325604 Zhejiang  
P.R. China

**Prüfzeichen Test Mark:**


Regular Production  
Surveillance  
Safety  
Type Approved

www.tuv.com  
ID 1111294689

**Geprüft nach Tested according to:**

EN 60947-2:2017+A1

**Geräteidentifikation**
**Product Identification**

**Produkt:** Moulded case circuit breaker  
*Product:* (Moulded case circuit breaker)

**Modell:** Modelle sind auf nächste(r) Seite(n) gelistet  
*Type:* *Type designation(s) are listed on the next page(s)*

**Technische Daten:** Technische Daten auf nächste(r) Seite(n) gelistet  
*Technical Data:* *Technical Data is listed on the next page(s)*

**Gültig ab:** 2025-01-10

*Valid from:*
**Zertifizierungsstelle:**
*Certification body:*
**Ausstellungsdatum:** 2025-01-10

*Date of issue:*

Wencai Zhang



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

*This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.*

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**
<http://www.tuv.com/safety> E-mail: [markcheck@tuv.com](mailto:markcheck@tuv.com)

Fax: +49 221 806-3935

# Zertifikat *Certificate*

**Zertifikatsnummer Certificate No.:**

R 50658154 0001

**Berichtsnummer Report No.:**

CN24J02U 001

**Produkt Product:** Moulded case circuit breaker  
(Moulded case circuit breaker)

**Modell Type:**
**Bezeichnung Designation:**

Code Designation : TGM3-abc/defgh  
(a=800; b=L, M, H, R; c=Blank, P, Z; d=3, 3N, 4; e=2, 3;  
f=00,08,10,18,21,23,30,38,41,43,45,47,50,52,54,56,58,59,  
66,68,71,75,77; g=Blank, 2; h=A, B, C, D)

Trademark : (Tengen(Logo))

Selectivity Category	:A
Interruption Medium	:Air
Electromagnetic Compatibility	:Environment A
Number of Poles	:3P,3P+N,4P
Rated Operation Voltage(Ue)	:AC380/400/415V
Rated Frequency	:50/60Hz
Rated Impulse Withstand Voltage(Uimp)	:12kV
Rated Insulation Voltage(Ui)	:1000V
Rated Current of Construction Breaks(Inm)	:800A
Conventional Free Air Thermal Current of Frame Size(Ith)	:800A
Breaking Capacity Level	:L,M,H,R
Rated Current Range of Thermo-magnetic or Magnetic Release(In):	Inm:800A:400/500/600/630/650/700/800A
Current Setting of Adjustable Overload Release:(Ir):	1.0In
Rated Instantaneous Short-circuit Current Setting:(Ii):	6/8/10In±20%(Power distribution), 12In±20%(Motor protection)
Rated Ultimate Short-circuit Breaking Capacity(Icu):	50kA(b=L),70kA(b=M),100kA(b=H),100kA(b=R)
Rated Service Short-circuit Breaking Capacity(Ics):	50kA(b=L),70kA(b=M),75kA(b=H),100kA(b=R)
Rated Duty	:Uninterrupted duty
Suitability for Using in IT System	:No
Suitability for Isolation	:Yes(3P;4P)
Method of Installation	:Fixed,Plug-in,Withdrawable

**Auxiliary and Control Circuit Parameters:**

Shunt Release(Us): AC220/230/240V,AC380/400/415V,50/60Hz;  
DC24V,DC110V,DC220V,Ui:690V,Uimp:4kV

Undervoltage Release: AC220/230/240V,AC380/400/415V;  
50/60Hz,Ui:800V,Uimp:4kV

**Auxiliary Switch or Alarm Contact Circuits:**

NO or NC, Ui:690V,Uimp:4kV,Ith=5A,AC-15:AC380/400/415V/0.3A;  
DC-13:DC110/220/250V/0.15A

**Motor Operating Mechanism:**

Ui:690V,Uimp:4kV,AC380/400/415V,50/60Hz,AC/DC110/220/230/240

ANLAGE (Appendix): 1

